


Air filter test data sheet

Test method : EN 779 / ASHRAE 52-76


Test report number	: A08056-SE	Model	:RBF-260
Date	:December 18, 2007	Manufacturer	: Filtrair
Initial resistance	: 51 Pa		
Final resistance	: 250 Pa	Depth	: 9 mm
Average arrestance	: 85 %	Media area	: 0.25 m ²
Average efficiency	: initial < 20 %	Temperature resistance	: up to 100 ° C
Dust holding capacity	: 435 g/m ²	Flammability (DIN 53438):	F1
Air velocity at test	: 2.0 m/s	Rated air flow	: 1800 m ³ /h
Classification (EN 779)	: G3		

Clean device

Air flow rate vs. resistance



Pressure drop and Arrestance vs. dust fed



Filtrair B.V.
P.O.Box 611, 8440 AP Heerenveen, The Netherlands
Tel. *31-513-626355, Fax *31-513-627306